



ADDENDUM No. ONE

Project: Des Plaines Public Library
Variable Frequency Drives Replacement

Address: 1501 Ellinwood Street
Des Plaines, IL 60016

Question: What are the motor specifications for the Variable Frequency Drives?

HVAC Mechanical room / 1st floor

- AHU-1 / Supply Fan / HP 50 / 480vac 3 phase / 100 amp
- AHU-1 / Return Fan / HP 30 / 480vac 3 phase / 100/70 amp
- Chilled Water Pump #3 West / HP 10 / 480vac 3 phase / 100/40 amp
- Chilled Water Pump #4 East / HP 10 / 480vac 3 phase / 100/40 amp
- Hot Water Pump #1 West / HP 7.5 / 480vac 3 phase / 100/30 amp
- Hot Water Pump #2 East / HP 7.5 / 480vac 3 phase / 100/30 amp

HVAC Mechanical room / 4th floor

- AHU-2 / Supply Fan / HP 50 / 480vac 3 phase / 100 amp
- AHU-2 / Return Fan / HP 30 / 480vac 3 phase / 100/70 amp

BID RETURN DATE: FRIDAY, AUGUST 28, 2015 AT 10:00 A.M.

THIS ADDENDUM IS TO BE ATTACHED TO YOUR BID AND ACKNOWLEDGED IN WRITING IN SPACE PROVIDED BELOW.

RECEIPT OF ADDENDUM NO. ONE ACKNOWLEDGED

BIDDER

DES PLAINES PUBLIC LIBRARY

August 17, 2015